



December 14, 2015

TO: Jerry W. Kittle
Director of Engineering – Innovative Engineering & Consulting, Inc.
755 West Carmel Drive, Suite 207
Carmel, IN 46032

RE: Harmony Subdivision Sections 4, 5, 6 and 7
Primary Plat Application – Waiver Requests – IECI Job No. 14115

In response to your letter dated October 30, 2015 requesting waivers for the above-mentioned project, see below:

- 1.) Centerline radius waiver – Public Works supports Estridge’s request to design roadway centerlines with a minimum radius of 100 feet based on the assumption that the posted speed limits will be 20 mph.
- 2.) Driveway separation – Public Works supports Estridge’s request to provide 30’ of separation between driveways and roadway intersections. The 30’ separation shall be measured from the intersection of the R/W, not the intersection of the centerline of the roadways. Also, no driveways shall be constructed within the limits of the ADA curb ramps.
- 3.) Alley details – Public Works supports Estridge’s request to utilize Westfield Standard Drawing G-10 for Alley details. Please note that there are additional requirements per the Standard Drawing for different applications and the City shall review any additional waiver with respect to these requirements. Also, this standard shall not be applied to Private Roadways.
- 4.) N/A
- 5.) Sight Distance – Public Works is willing to support Estridge’s waiver request given their consultant provides exhibits per Chapter 46 of the Indiana Design Manual proving that adequate intersection sight distance will be provided within the 20’ cuts. If adequate sight distance cannot be provided, Public Work will not support this waiver request.

If you have any additional questions or need any clarification please do not hesitate to ask.

Sincerely,

A handwritten signature in black ink, appearing to read "Phil Sundling", is written over a horizontal line.

Phil Sundling, PE
Project Management Supervisor
City of Westfield Public Works Department
2706 E. 171st Street
Westfield, IN 46074
(317) 517-1945
psundling@westfield.in.gov

Public Works Department

(317) 804-3100 office
(317) 804-3190 fax

2706 East 171st Street
Westfield, IN 46074
westfield.in.gov