



Kenton C. Ward, CFM
Surveyor of Hamilton County
Phone (317) 776-8495
Fax (317) 776-9628

Suite 188
One Hamilton County Square
Noblesville, Indiana 46060-2230

August 12, 2008

Banning Engineering
ATTN: Ryan Lindley
853 Columbia Road
Suite #101
Plainfield, IN 46168
VIA E-MAIL: rlindley@banning-eng.com

RE: Carey Shops – Goodwill Industries

Dear Mr. Robinson,

We have reviewed the construction plans submitted to the Hamilton County Surveyor's Office on August 5, 2008, for this project and have the following comments:

1. The proposed project falls in the incorporated area and MS4 jurisdiction of the City of Westfield.
2. The proposed project DOES fall in a Westfield Wellhead Protection Zone.
3. The proposed project falls in the Cool Creek Regulated Drain Watershed.
4. The Hamilton County Surveyor's Office agrees the detention volume for this proposed project has been accommodated in the master design.
5. Please submit an outlet permit to the Cool Creek Regulated Drain. The application is available on our website at <http://www.co.hamilton.in.us>, go to Departments, Surveyor, and Forms.
6. As part of this project, HCSO would appreciate if the regulated drain site outlet was finalized with our office. This would include any outstanding comments from the March 8, 2007 punch list letter from our inspector, Luther Cline, and submission of the as-built drawings for the regulated drain storm sewer. If there are any questions, please contact Luther Cline at 317-776-8495.

7. Please note that further comments may be necessary at a later date.

Should you have any questions, I can be reached at 317-776-8495.

Sincerely,

A handwritten signature in blue ink that reads "Greg Hoyes". The signature is written in a cursive style with a large initial "G".

Greg Hoyes, AC, CFM
Plan Reviewer

CC: Donna Luley – Westfield Public Works
Al Salzman – City of Westfield
Dave Lucas – HCHD
Luther Cline – HCSO
Michael Cox – Peacock Companies