



Kenton C. Ward, CFM
Surveyor of Hamilton County
 Phone (317) 776-8495
 Fax (317) 776-9628

Suite 188
One Hamilton County Square
Noblesville, Indiana 46060-2230

March 21, 2008

Douglas Realty Group
 ATTN: Douglas McAuley
 38 West 56th Street
 Indianapolis, IN 46208
 VIA FACSIMILE: 822-0692

RE: The Shoppes at Shamrock Springs

Dear Mr. McAuley:

We have reviewed the rezone request submitted to the Hamilton County Surveyor's Office on March 18, 2008 for this project and have the following comments:

1. This proposed project falls within the incorporated area and MS4 jurisdiction of the Town of Westfield.
2. This proposed project DOES NOT fall within a Westfield Wellhead Protection Zone.
3. This proposed project falls in the watersheds of the John Edwards Regulated Drain, the Williams Creed Regulated Drain, and the William Knight Regulated Drain.
4. Hamilton County Surveyor's Office has no objections to the rezone request.
5. Please note that this site will take a lot of planning for drainage, as it drains to 3 different regulated drains. It must comply with the Hamilton County Stormwater Technical Standards Manual and Westfield's Standards. I would recommend you schedule a meeting with HCSO before any detailed site drainage design begins.
6. Please note that further comments may be necessary at a later date.

Should you have any questions, I can be reached at 317-776-8495.

Sincerely,

Greg Hoyes, AC, CFM
 Plan Reviewer

CC: Donna Luley - Westfield Public Works
 Al Salzman - City of Westfield
 Dave Lucas - HCHD
 Steve Hardin - Baker & Daniels

