



Kenton C. Ward, CFM
Surveyor of Hamilton County
Phone (317) 776-8495
Fax (317) 776-9628

Suite 188
One Hamilton County Square
Noblesville, Indiana 46060-2230

July 16, 2010

Civil Site Group, Inc.
ATTN: Brian Cross, P.E.
643 Massachusetts Avenue
Suite 200
Indianapolis, IN 46204
VIA E-MAIL: bcross@civilsite.net

RE: Friedman Professional Offices

Dear Mr. Cross:

We have reviewed the construction plan submittal to the Hamilton County Surveyor's Office on July 1, 2010, for this project and have the following comments:

1. The proposed project falls in unincorporated area and MS4 jurisdiction of the City of Westfield.
2. The proposed project falls in the Vestal-Kirkendall Regulated Drain Watershed.
3. This proposed project DOES NOT fall within a Westfield Wellhead Protection Zone.
4. Please submit an indirect outlet permit for the indirect discharge into the Vestal-Kirkendall Regulated Drain. The application is available on our website at <http://www.co.hamilton.in.us>, go to Departments, Surveyor, and Forms.
5. This site has detention provided under the master drainage plan for Indiana Member Credit Union and the proposed drainage calculations are within the specification laid out by the master drainage plan.
6. Please submit revised plans after addressing all TAC agency comments.

7. Please note that further comments may be necessary at a later date.

Should you have any questions, I can be reached at 317-776-8495.

Sincerely,

A handwritten signature in blue ink that reads "Greg Hoyes". The signature is written in a cursive, flowing style.

Greg Hoyes, AC, CFM, CPESC
Plan Reviewer

CC: Pete White – Westfield Public Works
Kevin Todd – City of Westfield
Dave Lucas – HCHD