



Kenton C. Ward, CFM
Surveyor of Hamilton County
Phone (317) 776-8495
Fax (317) 776-9628

Suite 188
One Hamilton County Square
Noblesville, Indiana 46060-2230

December 7, 2011

Roger Ward Engineering, Inc.
ATTN: Victor Reyes
7474 Noel Road
Indianapolis, IN. 46278
VIA E-MAIL: VReyes@rw-engineering.com

RE: Interbody Site

Dear Mr. Reyes:

We have reviewed the construction plan submittal to the Hamilton County Surveyor's Office on December 2, 2011, for this project and have the following comments:

1. The proposed project falls in the incorporated area and MS4 jurisdiction of the City of Westfield.
2. The proposed project falls in the Anna Kendall/Cool Creek Regulated Drain Watershed.
3. This proposed project DOES NOT fall within a Westfield Wellhead Protection Zone.
4. Please submit an outlet permit for the discharge into the Anna Kendall Regulated Drain. The application is available on our website at <http://www.hamiltoncounty.in.gov/surveyor>, under the Forms page.
5. Please submit drainage calculations for this project that meet the allowable release rates as outlined in the Hamilton County Stormwater Management Technical Standard Manual.
6. Please label the 100 year elevation of the dry detention basin on the construction plans.

7. Please show the emergency flood spillway and flood routing on the construction plans.
8. Please submit revised plans after addressing all TAC agency comments.
9. Please note that further comments may be necessary at a later date.

Should you have any questions, I can be reached at 317-776-8495.

Sincerely,

A handwritten signature in blue ink that reads "Greg Hoyes". The signature is written in a cursive, flowing style.

Greg Hoyes, AC, CFM, CPESC
Plan Reviewer

CC: Pete White – Westfield Public Works
Kevin Todd – City of Westfield
Dave Lucas – HCHD